



Power

Schedule for Secondary School Rooms & Spaces

ID	ROOM/SPACE NAME	GPO	CM	OTH
HS401 GENERAL LEARNING UNIT				
HS401.01	General Learning Space - Adjoining	GENERAL POWER OUTLETS 2 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
HS401.02	General Learning Space with Independent Learning Area	GENERAL POWER OUTLETS 5 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
HS401.07	General Learning Space - Divisible	GENERAL POWER OUTLETS 5 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
HS401.03	Shared Learning Space with Practical Activities Area	GENERAL POWER OUTLETS 2 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
HS401.04	Seminar Room- General	GENERAL POWER OUTLETS 8 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
HS401.05	GLS Store Room	GENERAL POWER OUTLETS 1 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
HS401.06	Practical Activities Area	GENERAL POWER OUTLETS 2 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
HS402 SENIOR LEARNING UNIT				
HS402.01	Shared Study Space with Practical Activities Area	GENERAL POWER OUTLETS 3 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
HS403.01	Senior Learning Centre with Practical Activities Area	GENERAL POWER OUTLETS 4 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
HS404 SCIENCE LEARNING UNIT				
HS404.01	Science General Learning Space with Demonstration Bench	GENERAL POWER OUTLETS 5 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
HS404.10	Small Science General Learning Space	GENERAL POWER OUTLETS 5 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
HS404.02	Shared Science Laboratory	GENERAL POWER OUTLETS 15 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	POWER - OTHER Other power considerations may apply. Refer to Design Guide
HS404.03	Seminar Room - Lab/Workshop	GENERAL POWER OUTLETS 8 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
HS404.04	Science Preparation	GENERAL POWER OUTLETS 6 double socket outlets, 2 single socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
HS404.06	Apparatus Store Room	GENERAL POWER OUTLETS 1 single socket outlet	-	-



Power

Schedule for Secondary School Rooms & Spaces

ID	ROOM/SPACE NAME	GPO	CM	OTH
HS404.07	Apparatus Storage	GENERAL POWER OUTLETS 1 single socket outlet	-	-
HS404.08	Chemical Store Room	-	-	-
HS404.09	Botany/Zoology Room	GENERAL POWER OUTLETS 2 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
HS405 VISUAL ARTS LEARNING UNIT				
HS405.01	Visual Arts General Learning Space	GENERAL POWER OUTLETS 2 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
HS405.02	Visual Arts Learning Space with Art Trough	GENERAL POWER OUTLETS 2 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
HS405.03	Shared Visual Arts Workshop	GENERAL POWER OUTLETS For guidelines refer to Design Guide	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	POWER - OTHER Other power considerations may apply. Refer to Design Guide
HS405.04	Visual Arts Store Room	GENERAL POWER OUTLETS 1 single socket outlet	-	-
HS405.05	Visual Arts Project Store Room	GENERAL POWER OUTLETS 1 double socket outlet	-	-
HS405.06	Dark Room	GENERAL POWER OUTLETS For guidelines refer to Design Guide	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	POWER - OTHER Other power considerations may apply. Refer to Design Guide
HS413.01	Materials Workshop	GENERAL POWER OUTLETS For guidelines refer to Design Guide	-	POWER - OTHER Other power considerations may apply. Refer to Design Guide
HS413.02	Project Store Room	GENERAL POWER OUTLETS 1 double socket outlet	-	-
HS407 PERFORMANCE & FITNESS LEARNING UNIT				
HS406.01	Shared Health/PE & Performing Arts Workshop	GENERAL POWER OUTLETS 7 double socket outlets	-	-
HS406.02	Performing Arts Store Room	GENERAL POWER OUTLETS 1 double socket outlet	-	-
HS406.03	Seminar Room - Practice	GENERAL POWER OUTLETS 3 double socket outlets	-	-
HS407.02	PE & Fitness Store Room	GENERAL POWER OUTLETS 1 double socket outlet	-	-
HS407.04	General Learning Space - With Performance Area	GENERAL POWER OUTLETS 8 double socket outlets	-	-



Power

Schedule for Secondary School Rooms & Spaces

ID	ROOM/SPACE NAME	GPO	CM	OTH
HS408.01	Shared PE Fitness Laboratory with Wet Area	GENERAL POWER OUTLETS 2 double socket outlets	-	-
HS408.03	Change Room	GENERAL POWER OUTLETS 1 double socket outlet	-	-
HS409 TAS MAT 1 - KITCHEN				
HS409.01	Food & Textile Technology General Learning Space with Kitchen Demonstration Bench	GENERAL POWER OUTLETS 2 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
HS409.02	Food & Textile Technology General Learning Space with Sink	GENERAL POWER OUTLETS 2 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
HS409.03	Shared Domestic Kitchen	GENERAL POWER OUTLETS For guidelines refer to Design Guide	-	-
HS414.01	Semi-Commercial Kitchen	GENERAL POWER OUTLETS For guidelines refer to Design Guide	-	-
HS409.04	Kitchen - Store Room	GENERAL POWER OUTLETS 1 double socket outlet	-	-
HS409.05	Kitchen - Preparation	GENERAL POWER OUTLETS For guidelines refer to Design Guide	-	-
HS409.07	Pantry - Domestic	-	-	-
HS414.02	Pantry - Semi-Commercial	-	-	-
HS409.08	Laundry	GENERAL POWER OUTLETS 2 double socket outlets	-	-
HS410 TAS MAT 2 - WOOD & METAL				
HS410.01	Wood & Metal Technology General Learning Space - With Sink	GENERAL POWER OUTLETS For guidelines refer to Design Guide	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
HS410.02	Wood & Metal Technology General Learning Space	GENERAL POWER OUTLETS For guidelines refer to Design Guide	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
HS410.03	Shared Wood & Metal Workshop	GENERAL POWER OUTLETS For guidelines refer to Design Guide	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
HS410.04	Wood & Metal Materials Store Room	GENERAL POWER OUTLETS 1 double socket outlet	-	-
HS410.05	Wood & Metal Project Store Room	GENERAL POWER OUTLETS 1 double socket outlet	-	-



Power

Schedule for Secondary School Rooms & Spaces

ID	ROOM/SPACE NAME	GPO	CM	OTH
HS410.06	Materials Learning Space - Wood & Metal	GENERAL POWER OUTLETS For guidelines refer to Design Guide	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
HS411 MULTIMEDIA LEARNING UNIT				
HS411.01	Shared Multimedia Workshop	GENERAL POWER OUTLETS For guidelines refer to Design Guide	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
HS411.02	Multimedia Store Room	GENERAL POWER OUTLETS 1 double socket outlet	-	-
HS411.03	Multimedia Studio	GENERAL POWER OUTLETS For guidelines refer to Design Guide	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
HS412 LECTURE LEARNING UNIT				
HS412.01	Lecture Theatre	GENERAL POWER OUTLETS For guidelines refer to Design Guide	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
HS412.02	Lecture Store Room	GENERAL POWER OUTLETS 1 double socket outlet	-	-
HS430 SPECIAL EDUCATION LEARNING UNIT (IO/IS/P)				
HS430.01	General Learning Space - IO	GENERAL POWER OUTLETS 2 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
HS430.02	General Learning Space - IS/P	GENERAL POWER OUTLETS 3 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
HS430.10	Shared Practical Activities Area - IO/IS/P	GENERAL POWER OUTLETS For guidelines refer to Design Guide	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
HS430.20	GLS Store Room - IO/IS/P	GENERAL POWER OUTLETS 1 double socket outlet	-	-
HS440 SPECIAL EDUCATION LEARNING UNIT (BD/CD/ED)				
HS440.01	General Learning Space - BD/CD/ED	GENERAL POWER OUTLETS 4 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
HS440.10	Multipurpose Space - BD/CD/ED	GENERAL POWER OUTLETS For guidelines refer to Design Guide	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
HS440.20	Project Store Room - BD/CD/ED	GENERAL POWER OUTLETS 1 double socket outlet	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
HS450 SPECIAL EDUCATION LEARNING UNIT (TUTORIAL)				



Power

Schedule for Secondary School Rooms & Spaces

ID	ROOM/SPACE NAME	GPO	CM	OTH
HS450.01	Independent Learning Space - Tutorial	GENERAL POWER OUTLETS For guidelines refer to Design Guide	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
HS450.02	Tutorial Centre Seminar Room	GENERAL POWER OUTLETS 2 double socket outlets	-	-
HS501 LIBRARY				
HS501.01	Library Main Entry	GENERAL POWER OUTLETS For guidelines refer to Design Guide	-	-
HS501.03	Library Main Area	GENERAL POWER OUTLETS For guidelines refer to Design Guide	-	-
HS501.07	Printing/Photocopying Area	GENERAL POWER OUTLETS 3 double socket outlets	-	-
HS501.08	Seminar Room - Divisible	GENERAL POWER OUTLETS For guidelines refer to Design Guide	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
HS501.09	Library Administration	GENERAL POWER OUTLETS For guidelines refer to Design Guide	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
HS501.13	Computer Learning Space	GENERAL POWER OUTLETS For guidelines refer to Design Guide	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	POWER - OTHER Other power considerations may apply. Refer to Design Guide
HS501.14	Computer Store Room	GENERAL POWER OUTLETS 1 double socket outlet	-	-
HS501.15	Senior Study	GENERAL POWER OUTLETS 5 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
HS501.17	Careers Adviser's Office	GENERAL POWER OUTLETS 2 double socket outlets	-	-
HS501.18	System Administrator's Office	GENERAL POWER OUTLETS 4 double socket outlets	-	-
HS501.19	Communications Room	GENERAL POWER OUTLETS 8 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	POWER - OTHER Other power considerations may apply. Refer to Design Guide
HS502 MOVEMENT COMPLEX				
HS502.01	Gymnasium	GENERAL POWER OUTLETS For guidelines refer to Design Guide	-	-
HS502.03	Gymnasium - Extension	GENERAL POWER OUTLETS For guidelines refer to Design Guide	-	-
HS502.18	Gymnasium - Half Court	GENERAL POWER OUTLETS For guidelines refer to Design Guide	-	-



Power

Schedule for Secondary School Rooms & Spaces

ID	ROOM/SPACE NAME	GPO	CM	OTH
HS502.04	Movement Studio	GENERAL POWER OUTLETS For guidelines refer to Design Guide	-	-
HS502.05	Sports Equipment Store Room	GENERAL POWER OUTLETS 1 double socket outlet	-	-
HS502.06	Large Equipment Store Room	GENERAL POWER OUTLETS 1 double socket outlet	-	-
HS502.07	Outdoor Equipment Store Room	GENERAL POWER OUTLETS 1 double socket outlet	-	-
HS502.08	Chair Store Room	-	-	-
HS502.10	Movement Studio Store Room	GENERAL POWER OUTLETS 1 double socket outlet	-	-
HS502.11	Control Room	GENERAL POWER OUTLETS For guidelines refer to Design Guide	-	-
HS502.12	First Aid	GENERAL POWER OUTLETS 2 double socket outlets	-	-
HS502.13	Shower	-	-	-
HS502.15	Staff Shower	GENERAL POWER OUTLETS 1 double socket outlet	-	-
HS502.16	Stage	GENERAL POWER OUTLETS For guidelines refer to Design Guide	-	-
HS502.17	Demountable Platform	-	-	-
HS503 OUTDOOR COVERED WORKSHOP				
HS503.01	Shared Outdoor Covered Workshop	GENERAL POWER OUTLETS For guidelines refer to Design Guide	-	-
HS503.06	Outdoor Covered Workshop	GENERAL POWER OUTLETS For guidelines refer to Design Guide	-	-
HS503.02	Welding/Hot Metals Area	GENERAL POWER OUTLETS For guidelines refer to Design Guide	-	-
HS503.03	Kiln Space	-	-	-
HS503.04	LPG Store Room	-	-	-



Power

Schedule for Secondary School Rooms & Spaces

ID	ROOM/SPACE NAME	GPO	CM	OTH
HS503.05	Pottery Store Room	GENERAL POWER OUTLETS For guidelines refer to Design Guide	-	-
HS504 OUTDOOR LEARNING				
HS504.01	Outdoor Learning Space	GENERAL POWER OUTLETS For guidelines refer to Design Guide	-	-
HS504.02	Tiered Outdoor Learning Space	GENERAL POWER OUTLETS For guidelines refer to Design Guide	-	-
HS504.03	Outdoor Learning Space - Small Group	GENERAL POWER OUTLETS For guidelines refer to Design Guide	-	-
HS505 GAMES				
HS505.01	Games Court	-	-	-
HS505.03	Games Field	-	-	-
HS505.04	Batting Practice Nets	-	-	-
HS506 AGRICULTURE				
HS506.01	Agriculture Shed Workshop	GENERAL POWER OUTLETS 2 double socket outlets	-	-
HS506.02	Agriculture Tools Storage	GENERAL POWER OUTLETS 1 double socket outlet	-	-
HS506.03	Animal Space	GENERAL POWER OUTLETS 2 double socket outlets	-	-
HS506.04	Plant Space	GENERAL POWER OUTLETS 2 double socket outlets	-	-
HS506.05	Covered Area - Agriculture	GENERAL POWER OUTLETS 1 double socket outlet	-	-
HS506.06	Agriculture Plot	-	-	-
HS601 ADMINISTRATION UNIT				
HS601.01	Public Reception	GENERAL POWER OUTLETS Type 1 - 3 double socket outlets Type 2 - 2 double socket outlets	-	-



Power

Schedule for Secondary School Rooms & Spaces

ID	ROOM/SPACE NAME	GPO	CM	OTH
HS601.03	Student Reception	-	-	-
HS601.05	Student Waiting	-	-	-
HS601.06	Principal's Office / Meeting Room	GENERAL POWER OUTLETS 3 double socket outlets	-	-
HS601.07	Deputy Principal's Office	GENERAL POWER OUTLETS 2 double socket outlets	-	-
HS601.08	Interview Room / Office	GENERAL POWER OUTLETS 2 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
HS601.09	Interview Room / Meeting	GENERAL POWER OUTLETS 2 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
HS601.11	Administration - Clerical	GENERAL POWER OUTLETS For guidelines refer to Design Guide	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
HS601.14	Administration - Executive	GENERAL POWER OUTLETS Type 1 - 7 double socket outlets Type 2 - 5 double socket outlets Type 3 - 3 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
HS601.17	Store Room	GENERAL POWER OUTLETS 1 double socket outlet	-	-
HS601.18	Clinic	GENERAL POWER OUTLETS 2 double socket outlets	-	-
HS601.21	Visitor's Office	GENERAL POWER OUTLETS 2 double socket outlets	-	-
HS601.22	Tea Room	GENERAL POWER OUTLETS For guidelines refer to Design Guide	-	-
HS601.23	Utility Space	GENERAL POWER OUTLETS 2 double socket outlets	-	-
HS601.81	Entrance Zone	-	-	-
HS602 STAFF UNIT				
HS602.01	Staff Study	GENERAL POWER OUTLETS For guidelines refer to Design Guide	-	-
HS602.04	Staff Lounge	GENERAL POWER OUTLETS 5 double socket outlets, 5 single socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
HS602.08	Preparation/Printing	GENERAL POWER OUTLETS 6 double socket outlets	-	-



Power

Schedule for Secondary School Rooms & Spaces

ID	ROOM/SPACE NAME	GPO	CM	OTH
HS602.11	Staff Toilet	GENERAL POWER OUTLETS 1 double socket outlet	-	-
HS602.12	Access Shower/Toilet	GENERAL POWER OUTLETS 1 double socket outlet	-	POWER - OTHER Other power considerations may apply. Refer to Design Guide
HS603 STUDENT SERVICES UNIT				
HS603.01	Toilets	-	-	-
HS603.02	Drinking Facilities	-	-	POWER - OTHER Other power considerations may apply. Refer to Design Guide
HS603.03	Seating	-	-	-
HS603.04	Hand Washing Outlets	-	-	-
HS603.06	Access Shower/Toilet/Change	GENERAL POWER OUTLETS Type 2 - 2 double socket outlets Type 3 - 1 double socket outlet Type 4 - 1 double socket outlet	-	-
HS603.09	Laundry	-	-	-
HS604 CANTEEN				
HS604.01	Canteen	-	-	-
HS604.04	Canteen Office/Store Room	GENERAL POWER OUTLETS 2 double socket outlets	-	-
HS604.07	Vending Machines	GENERAL POWER OUTLETS 1 double socket outlet	-	-
HS605 STORAGE UNIT				
HS605.01	Archive Store Room	GENERAL POWER OUTLETS 1 double socket outlet	-	-
HS605.03	Garden Store Room	GENERAL POWER OUTLETS 1 double socket outlet	-	-
HS605.04	Bulk Store Room	GENERAL POWER OUTLETS 1 double socket outlet	-	-
HS605.05	Cleaning Supplies Store Room	GENERAL POWER OUTLETS 1 double socket outlet	-	-



Power

Schedule for Secondary School Rooms & Spaces

ID	ROOM/SPACE NAME	GPO	CM	OTH
HS605.06	Cleaning Distributed Store Room	GENERAL POWER OUTLETS 1 double socket outlet	-	-
HS606 COVERED OUTDOOR SPACE				
HS606.01	Covered Outdoor Space	-	-	-
HS607 ASSEMBLY COURT				
HS607.01	Quadrangle	GENERAL POWER OUTLETS 1 double socket outlet	-	-
HS607.02	Flagpole	-	-	-
HS607.21	Assembly Zone	-	-	-
HS608 PEDESTRIAN CIRCULATION				
HS608.01	Paved Areas	-	-	-
HS608.02	Paved Access	-	-	-
HS609 VEHICULAR CIRCULATION				
HS609.01	Service Roads	-	-	-
HS609.04	Bulk Waste Pad	-	-	-
HS609.05	Car Parking	-	-	-
HS609.06	Bus Zone	-	-	-
HS609.07	Bicycle Enclosure	-	-	-
HS609.08	Crossovers	-	-	-

HS610 OPEN SPACES



Power

Schedule for Secondary School Rooms & Spaces

ID	ROOM/SPACE NAME	GPO	CM	OTH
HS610.01	Open Space	-	-	-
HS610.11	Street Frontage Zone	-	-	-
HS610.12	Active Zone	-	-	-
HS610.13	Passive Zone	-	-	-
HS610.14	Boundary Zone	-	-	-
HS610.15	Out of Bounds Zone	-	-	-
HS610.16	Special Function Zone	-	-	-
HS611 SERVICES				
HS611.01	Dust Extraction Space	GENERAL POWER OUTLETS 1 double socket outlet	-	-
HS610.17	Services Zone	-	-	-
HS611.02	Main Switchroom	GENERAL POWER OUTLETS 2 double socket outlets	-	-
HS611.03	Distribution Board Cupboard	-	-	-
HS612 SITE				
HS612.01	Fencing	-	-	-
HS612.03	Waste Recycling	-	-	-
HS612.04	Signs	-	-	-
HS612.05	Site	-	-	-