



Fire Protection

Schedule for Primary School Rooms & Spaces

ID	ROOM/SPACE NAME	FD	FHR	PFE	OTH
PS401 HOME BASE UNIT					
PS401.01	Home Base with Practical Activities Area	FIRE DETECTION/ALARMS Fire detection/alarms to comply with NCC.	FIRE HOSE REEL School Classrooms have exemption from provision of coverage by FHR under NCC	PORTABLE FIRE EXTINGUISHER/ BLANKET Portable fire extinguisher required where Fire Hose Reel coverage not provided to comply with NCC.	-
PS401.11	Home Base Store Room	-	-	-	-
PS401.21	Withdrawal Room	-	FIRE HOSE REEL Fire Hose Reels as required to comply with NCC	-	-
PS401.22	Shared Withdrawal Room	-	FIRE HOSE REEL Fire Hose Reels as required to comply with NCC	-	-
PS401.31	Practical Activities Area	-	-	PORTABLE FIRE EXTINGUISHER/ BLANKET Fire blanket required. Portable fire extinguisher where required by NCC.	-
PS401.32	Shared Practical Activities Area	-	-	PORTABLE FIRE EXTINGUISHER/ BLANKET Fire blanket required. Portable fire extinguisher where required by NCC.	-
PS401.41	Personal Effects Storage	-	-	-	-
PS430 SPECIAL EDUCATION LEARNING UNIT - IO/IS/P					
PS430.01	Home Base with Practical Activities Area - IO	FIRE DETECTION/ALARMS Fire detection/alarms to comply with NCC.	FIRE HOSE REEL School Classrooms have exemption from provision of coverage by FHR under NCC	PORTABLE FIRE EXTINGUISHER/ BLANKET Portable fire extinguisher required where Fire Hose Reel coverage not provided to comply with NCC.	-
PS430.02	Home Base with Practical Activities Area - IS/P	FIRE DETECTION/ALARMS Fire detection/alarms to comply with NCC.	FIRE HOSE REEL School Classrooms have exemption from provision of coverage by FHR under NCC	PORTABLE FIRE EXTINGUISHER/ BLANKET Portable fire extinguisher required where Fire Hose Reel coverage not provided to comply with NCC.	-
PS430.11	Home Base Store Room - IO/IS/P	-	FIRE HOSE REEL Fire Hose Reels as required to comply with NCC	-	-
PS430.21	Withdrawal Area - IO/IS/P	-	FIRE HOSE REEL Fire Hose Reels as required to comply with NCC	-	-



Fire Protection

Schedule for Primary School Rooms & Spaces

ID	ROOM/SPACE NAME	FD	FHR	PFE	OTH
PS430.22	Shared Withdrawal Room - IO/IS/P	-	FIRE HOSE REEL Fire Hose Reels as required to comply with NCC	-	-
PS430.31	Practical Activities Area - IO/IS/P	-	FIRE HOSE REEL Fire Hose Reels as required to comply with NCC	PORTABLE FIRE EXTINGUISHER/ BLANKET Fire blanket required. Portable fire extinguisher where required by NCC.	-
PS430.32	Shared Practical Activities Area - IO/IS/P	-	FIRE HOSE REEL Fire Hose Reels as required to comply with NCC	PORTABLE FIRE EXTINGUISHER/ BLANKET Fire blanket required. Portable fire extinguisher where required by NCC.	-
PS430.41	Personal Effects Storage - IO/IS/P	-	-	-	-
PS440 SPECIAL EDUCATION LEARNING UNIT - BD/CD/ED					
PS440.01	Home Base with Practical Activities Area - BD/CD/ED	FIRE DETECTION/ALARMS Fire detection/alarms to comply with NCC.	FIRE HOSE REEL School Classrooms have exemption from provision of coverage by FHR under NCC	PORTABLE FIRE EXTINGUISHER/ BLANKET Portable fire extinguisher required where Fire Hose Reel coverage not provided to comply with NCC.	-
PS440.31	Practical Activities Area - BD/CD/ED	FIRE DETECTION/ALARMS Fire detection/alarms to comply with NCC.	FIRE HOSE REEL Fire Hose Reels as required to comply with NCC	PORTABLE FIRE EXTINGUISHER/ BLANKET Fire blanket required. Portable fire extinguisher where required by NCC.	-
PS501 LIBRARY UNIT					
PS501.01	Library Main Area - Small	-	FIRE HOSE REEL Fire Hose Reels as required to comply with NCC	PORTABLE FIRE EXTINGUISHER/ BLANKET Portable fire extinguisher required when electrical equipment located in room or adjacent Communications room to comply with NCC.	-
PS501.03	Library Main Area - Large	-	FIRE HOSE REEL Fire Hose Reels as required to comply with NCC	PORTABLE FIRE EXTINGUISHER/ BLANKET Portable fire extinguisher required when electrical equipment located in room or adjacent Communications room to comply with NCC.	-
PS501.11	Office / Workroom	-	FIRE HOSE REEL Fire Hose Reels as required to comply with NCC	PORTABLE FIRE EXTINGUISHER/ BLANKET Portable fire extinguisher/fire blanket to comply with NCC.	-
PS501.12	Shared Office / Workroom	-	FIRE HOSE REEL Fire Hose Reels as required to comply with NCC	-	-



Fire Protection

Schedule for Primary School Rooms & Spaces

ID	ROOM/SPACE NAME	FD	FHR	PFE	OTH
PS501.21	Communications Room	-	FIRE HOSE REEL Fire Hose Reels as required to comply with NCC	PORTABLE FIRE EXTINGUISHER/ - BLANKET Portable fire extinguisher to be located adjacent to door either inside or outside room to comply with NCC.	-
PS501.31	KLA Resource Store Room	-	FIRE HOSE REEL Fire Hose Reels as required to comply with NCC	-	-
PS502 SPECIAL PROGRAMS UNIT					
PS502.01	Special Programs Room	FIRE DETECTION/ALARMS Fire detection/alarms to comply with NCC.	FIRE HOSE REEL Fire Hose Reels as required to comply with NCC	PORTABLE FIRE EXTINGUISHER/ - BLANKET Portable fire extinguisher /fire blanket required to comply with NCC.	-
PS502.03	Special Programs Store Room	-	FIRE HOSE REEL Fire Hose Reels as required to comply with NCC	-	-
PS503 COMMUNAL HALL UNIT					
PS503.01	Communal Hall - Small	FIRE DETECTION/ALARMS Fire detection/alarms to comply with NCC.	FIRE HOSE REEL Fire Hose Reels as required to comply with NCC	PORTABLE FIRE EXTINGUISHER/ - BLANKET Portable fire extinguisher /fire blanket required to comply with NCC.	-
PS503.02	Communal Hall - Large	FIRE DETECTION/ALARMS Fire detection/alarms to comply with NCC.	FIRE HOSE REEL Fire Hose Reels as required to comply with NCC	PORTABLE FIRE EXTINGUISHER/ - BLANKET Portable fire extinguisher /fire blanket required to comply with NCC.	-
PS503.11	Chair Store Room	-	FIRE HOSE REEL Fire Hose Reels as required to comply with NCC	-	-
PS503.21	PE Store Room	-	FIRE HOSE REEL Fire Hose Reels as required to comply with NCC	-	-
PS503.31	Sports Store Room	-	FIRE HOSE REEL Fire Hose Reels as required to comply with NCC	-	-
PS503.41	Performance Store Room	-	FIRE HOSE REEL Fire Hose Reels as required to comply with NCC	-	-



Fire Protection

Schedule for Primary School Rooms & Spaces

ID	ROOM/SPACE NAME	FD	FHR	PFE	OTH
PS503.51	Sound Cupboard	-	-	-	-
PS504 COVERED OUTDOOR LEARNING AREA (COLA)					
PS504.01	Covered Outdoor Learning Area (COLA)	-	-	-	-
PS504.03	Covered Outdoor Space	-	-	-	-
PS505 GAMES UNIT					
PS505.01	Games Court	-	-	-	-
PS506 KILN UNIT					
PS506.01	Kiln Room	-	-	-	-
PS601.01	Entry Vestibule	-	FIRE HOSE REEL Fire Hose Reels as required to comply with NCC	-	-
PS601.11	Principal's Office	-	FIRE HOSE REEL Fire Hose Reels as required to comply with NCC	-	-
PS601.12	Principal / Meeting Room	-	FIRE HOSE REEL Fire Hose Reels as required to comply with NCC	-	-
PS601.13	Deputy Principal's Office	-	FIRE HOSE REEL Fire Hose Reels as required to comply with NCC	-	-



Fire Protection

Schedule for Primary School Rooms & Spaces

ID	ROOM/SPACE NAME	FD	FHR	PFE	OTH
PS601.14	Deputy Principal - Double Office	-	FIRE HOSE REEL Fire Hose Reels as required to comply with NCC	-	-
PS601.15	Interview Room / Office	-	FIRE HOSE REEL Fire Hose Reels as required to comply with NCC	-	-
PS601.16	Interview Room	-	FIRE HOSE REEL Fire Hose Reels as required to comply with NCC	-	-
PS601.21	Clerical / Printing	FIRE DETECTION/ALARMS Fire detection/alarms to comply with NCC.	FIRE HOSE REEL Fire Hose Reels as required to comply with NCC	PORTABLE FIRE EXTINGUISHER/ BLANKET Portable fire extinguisher required where electrical equipment located in space to comply with NCC.	-
PS601.23	Clerical/Printing/Workroom	FIRE DETECTION/ALARMS Fire detection/alarms to comply with NCC.	FIRE HOSE REEL Fire Hose Reels as required to comply with NCC	PORTABLE FIRE EXTINGUISHER/ BLANKET Portable fire extinguisher required where electrical equipment located in space to comply with NCC.	-
PS601.41	Security Store Room	-	-	-	-
PS601.51	Sick Bay	-	FIRE HOSE REEL Fire Hose Reels as required to comply with NCC	-	-
PS601.71	Community Clinic	-	FIRE HOSE REEL Fire Hose Reels as required to comply with NCC	-	-
PS601.81	Entrance Zone	-	-	-	-
PS602 STAFF UNIT					
PS602.01	Staff Room	FIRE DETECTION/ALARMS Fire detection/alarms to comply with NCC.	FIRE HOSE REEL Fire Hose Reels as required to comply with NCC	PORTABLE FIRE EXTINGUISHER/ BLANKET Fire Blanket required Portable fire extinguisher where required to comply with NCC.	-
PS602.03	Staff Room - Adjoining Annexe	FIRE DETECTION/ALARMS Fire detection/alarms to comply with NCC.	FIRE HOSE REEL Fire Hose Reels as required to comply with NCC	PORTABLE FIRE EXTINGUISHER/ BLANKET Fire Blanket required Portable fire extinguisher where required to comply with NCC.	-



Fire Protection

Schedule for Primary School Rooms & Spaces

ID	ROOM/SPACE NAME	FD	FHR	PFE	OTH
PS602.11	Staff Toilet	-	-	-	-
PS602.12	Access Shower/Toilet	-	-	-	-
PS602.21	Staff Room Annexe	-	-	-	-
PS603 STUDENT AMENITIES					
PS603.01	Toilets	-	-	-	-
PS603.03	Drinking Facilities	-	-	-	-
PS603.04	Hand Washing Outlets	-	-	-	-
PS603.05	Seating	-	-	-	-
PS603.06	Access Shower/Toilet/Change	-	-	-	-
PS603.09	Laundry	-	FIRE HOSE REEL Fire Hose Reels as required to comply with NCC	-	-
PS604 CANTEEN UNIT					
PS604.01	Canteen	FIRE DETECTION/ALARMS Fire detection/alarms to comply with NCC.	FIRE HOSE REEL Fire Hose Reels as required to comply with NCC	PORTABLE FIRE EXTINGUISHER/ BLANKET Portable fire extinguisher and fire blanket required - to comply with NCC.	-
PS604.11	Canteen Office / Store Room	FIRE DETECTION/ALARMS Fire detection/alarms to comply with NCC.	FIRE HOSE REEL Fire Hose Reels as required to comply with NCC	PORTABLE FIRE EXTINGUISHER/ BLANKET Portable fire extinguisher/fire blanket where required to comply with NCC.	-



Fire Protection

Schedule for Primary School Rooms & Spaces

ID	ROOM/SPACE NAME	FD	FHR	PFE	OTH
PS604.21	Canteen Servery Covered Area	-	-	-	-
PS605 STORAGE UNIT					
PS605.01	Garden Store Room	-	-	PORTABLE FIRE EXTINGUISHER/ BLANKET Portable fire extinguisher required to comply with NCC.	-
PS605.11	Bulk Store Room	-	-	PORTABLE FIRE EXTINGUISHER/ BLANKET Portable fire extinguisher required to comply with NCC.	-
PS605.21	Cleaning Supplies Store Room	-	-	PORTABLE FIRE EXTINGUISHER/ BLANKET Portable fire extinguisher required to comply with NCC.	-
PS605.31	Cleaning Distributed Store Room	-	-	PORTABLE FIRE EXTINGUISHER/ BLANKET Portable fire extinguisher/fire blanket where required to comply with NCC.	-
PS607 ASSEMBLY COURT					
PS607.01	Assembly Area	-	-	-	-
PS607.11	Flagpole	-	-	-	-
PS607.21	Assembly Zone	-	-	-	-
PS608 PEDESTRIAN CIRCULATION					
PS608.01	Paved Areas	-	-	-	-
PS608.02	Paved Access	-	-	-	-
PS609 VEHICULAR CIRCULATION					
PS609.01	Service Roads	-	-	-	-
PS609.11	Bulk Waste Pad	-	-	-	-
PS609.21	Car Parking	-	-	-	-



Fire Protection

Schedule for Primary School Rooms & Spaces

ID	ROOM/SPACE NAME	FD	FHR	PFE	OTH
PS609.31	Bus Zone	-	-	-	-
PS609.41	Bicycle Storage Area	-	-	-	-
PS609.51	Crossovers	-	-	-	-
PS610 OPEN SPACES					
PS610.01	Free Play Area	-	-	-	-
PS610.02	Passive Play/Open Areas	-	-	-	-
PS610.11	Street Frontage Zone	-	-	-	-
PS610.12	Active Zone	-	-	-	-
PS610.13	Passive Zone	-	-	-	-
PS610.14	Boundary Zone	-	-	-	-
PS610.15	Out of Bounds Zone	-	-	-	-
PS610.16	Special Function Zone	-	-	-	-
PS611 SERVICES					
PS611.01	Main Switchboard Cupboard	-	-	PORTABLE FIRE EXTINGUISHER/ - BLANKET Portable fire extinguisher/fire blanket - to comply with NCC.	-
PS611.02	Distribution Board Cupboard	-	-	PORTABLE FIRE EXTINGUISHER/ - BLANKET Portable fire extinguisher/fire blanket - to comply with NCC.	-
PS611.11	Services Zone	-	-	-	-

PS612 SITE



Fire Protection

Schedule for Primary School Rooms & Spaces

ID	ROOM/SPACE NAME	FD	FHR	PFE	OTH
PS612.01	Fencing	-	-	-	-
PS612.11	Waste Recycling	-	-	-	-
PS612.21	Signs	-	-	-	-
PS612.31	Site	-	-	-	-