



Illumination

Schedule for Primary School Rooms & Spaces

ID	ROOM/SPACE NAME	LUX	LC	OTH
PS401 HOME BASE UNIT				
PS401.01	Home Base with Practical Activities Area	LUX LEVEL 240 lux	LIGHTING CONTROL Minimum 2 circuits. Refer to Design Guide	-
PS401.11	Home Base Store Room	LUX LEVEL 160 lux	-	-
PS401.21	Withdrawal Room	LUX LEVEL 240 lux	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS401.22	Shared Withdrawal Room	LUX LEVEL 240 lux	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS401.31	Practical Activities Area	LUX LEVEL 240 lux	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS401.32	Shared Practical Activities Area	LUX LEVEL 240 lux	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS401.41	Personal Effects Storage	LUX LEVEL 160 lux	-	-
PS430 SPECIAL EDUCATION LEARNING UNIT - IO/IS/P				
PS430.01	Home Base with Practical Activities Area - IO	LUX LEVEL 240 lux	LIGHTING CONTROL Minimum 2 circuits. Refer to Design Guide	-
PS430.02	Home Base with Practical Activities Area - IS/P	LUX LEVEL 240 lux	LIGHTING CONTROL Minimum 2 circuits. Refer to Design Guide	-
PS430.11	Home Base Store Room - IO/IS/P	LUX LEVEL 160 lux	-	-
PS430.21	Withdrawal Area - IO/IS/P	LUX LEVEL 240 lux	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS430.22	Shared Withdrawal Room - IO/IS/P	LUX LEVEL 240 lux	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS430.31	Practical Activities Area - IO/IS/P	LUX LEVEL 240 lux	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS430.32	Shared Practical Activities Area - IO/IS/P	LUX LEVEL 240 lux	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS430.41	Personal Effects Storage - IO/IS/P	LUX LEVEL 160 lux	-	-
PS440 SPECIAL EDUCATION LEARNING UNIT - BD/CD/ED				
PS440.01	Home Base with Practical Activities Area - BD/CD/ED	LUX LEVEL 240 lux	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-



Illumination

Schedule for Primary School Rooms & Spaces

ID	ROOM/SPACE NAME	LUX	LC	OTH
PS440.31	Practical Activities Area - BD/CD/ED	LUX LEVEL 240 lux	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS501 LIBRARY UNIT				
PS501.01	Library Main Area - Small	LUX LEVEL 240 lux	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS501.03	Library Main Area - Large	LUX LEVEL 240 lux	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS501.11	Office / Workroom	LUX LEVEL 240 lux	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS501.12	Shared Office / Workroom	LUX LEVEL 240 lux	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS501.21	Communications Room	LUX LEVEL 240 lux	-	-
PS501.31	KLA Resource Store Room	LUX LEVEL 160 lux	-	-
PS502 SPECIAL PROGRAMS UNIT				
PS502.01	Special Programs Room	LUX LEVEL 240 lux	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS502.03	Special Programs Store Room	LUX LEVEL 160 lux	-	-
PS503 COMMUNAL HALL UNIT				
PS503.01	Communal Hall - Small	LUX LEVEL 160 lux	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS503.02	Communal Hall - Large	LUX LEVEL 160 lux	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS503.11	Chair Store Room	LUX LEVEL 160 lux	-	-
PS503.21	PE Store Room	LUX LEVEL 160 lux	-	-
PS503.31	Sports Store Room	LUX LEVEL 160 lux	-	-
PS503.41	Performance Store Room	LUX LEVEL 160 lux	-	-



Illumination

Schedule for Primary School Rooms & Spaces

ID	ROOM/SPACE NAME	LUX	LC	OTH
PS503.51	Sound Cupboard	LUX LEVEL 160 lux	-	-
PS504 COVERED OUTDOOR LEARNING AREA (COLA)				
PS504.01	Covered Outdoor Learning Area (COLA)	LUX LEVEL Lux level considerations must be taken into account. Refer to design Guide	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS504.03	Covered Outdoor Space	LUX LEVEL Lux level considerations must be taken into account. Refer to design Guide	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS505 GAMES UNIT				
PS505.01	Games Court	LUX LEVEL Lux level considerations must be taken into account. Refer to design Guide	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS506 KILN UNIT				
PS506.01	Kiln Room	LUX LEVEL 160 lux	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS601.01	Entry Vestibule	LUX LEVEL 320 lux	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS601.11	Principal's Office	LUX LEVEL 320 lux	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS601.12	Principal / Meeting Room	LUX LEVEL 320 lux	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS601.13	Deputy Principal's Office	LUX LEVEL 320 lux	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS601.14	Deputy Principal - Double Office	LUX LEVEL 320 lux	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS601.15	Interview Room / Office	LUX LEVEL 320 lux	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS601.16	Interview Room	LUX LEVEL 320 lux	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS601.21	Clerical / Printing	LUX LEVEL 320 lux	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS601.23	Clerical/Printing/Workroom	LUX LEVEL 320 lux	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS601.41	Security Store Room	LUX LEVEL 240 lux	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-



Illumination

Schedule for Primary School Rooms & Spaces

ID	ROOM/SPACE NAME	LUX	LC	OTH
PS601.51	Sick Bay	LUX LEVEL 240 lux	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS601.71	Community Clinic	LUX LEVEL 240 lux	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS601.81	Entrance Zone	-	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS602 STAFF UNIT				
PS602.01	Staff Room	LUX LEVEL 240 lux	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS602.03	Staff Room - Adjoining Annexe	LUX LEVEL 240 lux	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS602.11	Staff Toilet	LUX LEVEL 160 lux	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS602.12	Access Shower/Toilet	LUX LEVEL 160 lux	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS602.21	Staff Room Annexe	LUX LEVEL 240 lux	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS603 STUDENT AMENITIES				
PS603.01	Toilets	LUX LEVEL 160 lux	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS603.03	Drinking Facilities	-	-	-
PS603.04	Hand Washing Outlets	-	-	-
PS603.05	Seating	-	-	-
PS603.06	Access Shower/Toilet/Change	LUX LEVEL 160 lux	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS603.09	Laundry	LUX LEVEL 320 lux	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS604 CANTEEN UNIT				
PS604.01	Canteen	LUX LEVEL 320 lux	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-



Illumination

Schedule for Primary School Rooms & Spaces

ID	ROOM/SPACE NAME	LUX	LC	OTH
PS604.11	Canteen Office / Store Room			
PS604.21	Canteen Servery Covered Area	LUX LEVEL 320 lux	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS605 STORAGE UNIT				
PS605.01	Garden Store Room	LUX LEVEL 160 lux	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS605.11	Bulk Store Room	LUX LEVEL 160 lux	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS605.21	Cleaning Supplies Store Room	LUX LEVEL 160 lux	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS605.31	Cleaning Distributed Store Room	LUX LEVEL 160 lux	LIGHTING CONTROL Lighting control requirements as outlined in Design Guide.	-
PS607 ASSEMBLY COURT				
PS607.01	Assembly Area	-	-	-
PS607.11	Flagpole	-	-	-
PS607.21	Assembly Zone	-	-	-
PS608 PEDESTRIAN CIRCULATION				
PS608.01	Paved Areas	-	-	-
PS608.02	Paved Access	-	-	-
PS609 VEHICULAR CIRCULATION				
PS609.01	Service Roads	-	-	-
PS609.11	Bulk Waste Pad	-	-	-
PS609.21	Car Parking	-	-	-
PS609.31	Bus Zone	-	-	-
PS609.41	Bicycle Storage Area	-	-	-
PS609.51	Crossovers	-	-	-
PS610 OPEN SPACES				
PS610.01	Free Play Area	-	-	-
PS610.02	Passive Play/Open Areas	-	-	-
PS610.11	Street Frontage Zone	-	-	-



Illumination

Schedule for Primary School Rooms & Spaces

ID	ROOM/SPACE NAME	LUX	LC	OTH
PS610.12	Active Zone	-	-	-
PS610.13	Passive Zone	-	-	-
PS610.14	Boundary Zone	-	-	-
PS610.15	Out of Bounds Zone	-	-	-
PS610.16	Special Function Zone	-	-	-
PS611 SERVICES				
PS611.01	Main Switchboard Cupboard	-	-	-
PS611.02	Distribution Board Cupboard	-	-	-
PS611.11	Services Zone	-	-	-
PS612 SITE				
PS612.01	Fencing	-	-	-
PS612.11	Waste Recycling	-	-	-
PS612.21	Signs	-	-	-
PS612.31	Site	-	-	-