



Cooling

Schedule for BD/CD/ED School Rooms & Spaces

ID	ROOM/SPACE NAME	MC	FAN	OTH
SSP440 HOME BASE UNIT (BD/CD/ED)				
SSP440.01	Home Base - BD/CD/ED	MECHANICAL COOLING Provide mechanical cooling where regionally appropriate. Refer to Design Guide	FAN Fan required. Refer to Design Guide	-
SSP440.11	Home Base Store - BD/CD/ED	-	-	-
SSP501 LIBRARY				
SSP501.01	Library Main Area	-	-	-
SSP501.11	Office/Workroom	MECHANICAL COOLING Provide mechanical cooling where regionally appropriate. Refer to Design Guide	FAN Fan required. Refer to Design Guide	-
SSP501.21	Communications Room	MECHANICAL COOLING Provide mechanical cooling where regionally appropriate. Refer to Design Guide	-	Refer to design guide.
SSP501.32	KLA Resource Store	-	-	-
SSP502 SPECIAL PROGRAMS UNIT				
SSP502.10	Special Programs Room - BD/CD/ED	-	-	-
SSP502.15	Kitchenette - BD/CD/ED	MECHANICAL COOLING Provide mechanical cooling where regionally appropriate. Refer to Design Guide	FAN Fan required. Refer to Design Guide	-
SSP502.21	Project Store	-	-	-
SSP504 COVERED OUTDOOR LEARNING AREA (COLA)				
SSP504.07	Covered Outdoor Seating Area	-	-	-
SSP502 GAMES				
SSP505.02	Games Court	-	-	-
SSP601 ADMINISTRATION UNIT				
SSP601.01	Entry Vestibule	-	-	-
SSP601.11	Principal	MECHANICAL COOLING Provide mechanical cooling where regionally appropriate. Refer to Design Guide	FAN Fan required. Refer to Design Guide	-



Cooling

Schedule for BD/CD/ED School Rooms & Spaces

ID	ROOM/SPACE NAME	MC	FAN	OTH
SSP601.15	Interview	MECHANICAL COOLING Provide mechanical cooling where regionally appropriate. Refer to Design Guide	FAN Fan required. Refer to Design Guide	-
SSP601.21	Clerical/Printing	MECHANICAL COOLING Provide mechanical cooling where regionally appropriate. Refer to Design Guide	FAN Fan required. Refer to Design Guide	-
SSP601.41	Security Store	-	-	-
SSP601.51	Sick Bay	MECHANICAL COOLING Provide mechanical cooling where regionally appropriate. Refer to Design Guide	FAN Fan required. Refer to Design Guide	-
SSP601.81	Entrance Zone	-	-	-

SSP602 STAFF UNIT

SSP602.01	Staff Room	MECHANICAL COOLING Provide mechanical cooling where regionally appropriate. Refer to Design Guide	FAN Fan required. Refer to Design Guide	-
SSP602.30	Staff Toilet	-	-	-

SSP603 STUDENT SERVICES UNIT

SSP603.02	Toilets	-	-	-
SSP603.04	Hand Washing Outlets	-	-	-
SSP603.05	Drinking Facilities	-	-	-
SSP603.11	Access Shower/Toilet	-	-	-
SSP603.30	Seating	-	-	-

SSP605 STORAGE UNIT

SSP605.11	Bulk Store	-	-	-
SSP605.21	Cleaning Supplies Store	-	-	-
SSP605.31	Cleaning Distributed Store	-	-	-

SSP607 ASSEMBLY COURT

SSP607.01	Assembly Area	-	-	-
SSP607.11	Flagpole	-	-	-
SSP607.21	Assembly Zone	-	-	-

SSP608 PEDESTRIAN CIRCULATION

SSP608.01	Paved Areas	-	-	-
-----------	-------------	---	---	---



Cooling

Schedule for BD/CD/ED School Rooms & Spaces

ID	ROOM/SPACE NAME	MC	FAN	OTH
SSP608.02	Paved Access	-	-	-
SSP609 VEHICULAR CIRCULATION				
SSP609.01	Service Roads	-	-	-
SSP609.11	Bulk Waste Pad	-	-	-
SSP609.21	Car Parking	-	-	-
SSP609.51	Crossovers	-	-	-
SSP609.61	Student Set Down	-	-	-
SSP610 OPEN SPACES				
SSP610.01	Free Play Area	-	-	-
SSP610.02	Passive Play/Open Areas	-	-	-
SSP610.11	Street Frontage Zone	-	-	-
SSP610.12	Active Zone	-	-	-
SSP610.13	Passive Zone	-	-	-
SSP610.14	Boundary Zone	-	-	-
SSP610.15	Out of Bounds Zone	-	-	-
SSP610.16	Special Function Zone	-	-	-
SSP611 SERVICES				
SSP611.01	Main Switchboard Cupboard	-	-	-
SSP611.02	Distribution Board Cupboard	-	-	-
SSP611.11	Services Zone	-	-	-
SSP612 SITE				
SSP612.01	Boundary Fencing	-	-	-
SSP612.03	Zone Fencing	-	-	-
SSP612.21	Signs	-	-	-