



# Fire Protection

Schedule for BD/CD/ED School Rooms & Spaces

ID	ROOM/SPACE NAME	FD	FHR	PFE	OTH
<b>SSP440 HOME BASE UNIT (BD/CD/ED)</b>					
SSP440.01	Home Base - BD/CD/ED	FIRE DETECTION/ALARMS Fire detection/alarms to comply with NCC	FIRE HOSE REEL Fire Hose Reel as required to comply with NCC	PORTABLE FIRE EXTINGUISHER/ - BLANKET Portable fire extinguisher/fire blanket required. Comply with NCC	
SSP440.11	Home Base Store - BD/CD/ED	FIRE DETECTION/ALARMS Fire detection/alarms to comply with NCC	FIRE HOSE REEL Fire Hose Reel as required to comply with NCC	-	-
<b>SSP501 LIBRARY</b>					
SSP501.01	Library Main Area	-	-	-	-
SSP501.11	Office/Workroom	FIRE DETECTION/ALARMS Fire detection/alarms to comply with NCC	-	-	-
SSP501.21	Communications Room	FIRE DETECTION/ALARMS Fire detection/alarms to comply with NCC	-	-	-
SSP501.32	KLA Resource Store	FIRE DETECTION/ALARMS Fire detection/alarms to comply with NCC	-	-	-
<b>SSP502 SPECIAL PROGRAMS UNIT</b>					
SSP502.10	Special Programs Room - BD/CD/ED	-	-	PORTABLE FIRE EXTINGUISHER/ - BLANKET Portable fire extinguisher required. Comply with NCC	
SSP502.15	Kitchenette - BD/CD/ED	FIRE DETECTION/ALARMS Fire detection/alarms to comply with NCC	-	PORTABLE FIRE EXTINGUISHER/ - BLANKET Portable fire extinguisher required. Comply with NCC	
SSP502.21	Project Store	FIRE DETECTION/ALARMS Fire detection/alarms to comply with NCC	-	-	-
<b>SSP504 COVERED OUTDOOR LEARNING AREA (COLA)</b>					
SSP504.07	Covered Outdoor Seating Area	-	-	-	-
<b>SSP502 GAMES</b>					
SSP505.02	Games Court	-	-	-	-
<b>SSP601 ADMINISTRATION UNIT</b>					
SSP601.01	Entry Vestibule	-	-	-	-
SSP601.11	Principal	-	-	-	-
SSP601.15	Interview	-	-	-	-



# Fire Protection

Schedule for BD/CD/ED School Rooms & Spaces

ID	ROOM/SPACE NAME	FD	FHR	PFE	OTH
SSP601.21	Clerical/Printing	-	-	-	-
SSP601.41	Security Store	-	-	-	-
SSP601.51	Sick Bay	-	-	-	-
SSP601.81	Entrance Zone	-	-	-	-
<b>SSP602 STAFF UNIT</b>					
SSP602.01	Staff Room	-	-	-	-
SSP602.30	Staff Toilet	FIRE DETECTION/ALARMS Fire detection/alarms to comply with	-	PORTABLE FIRE EXTINGUISHER/ BLANKET	-
<b>SSP603 STUDENT SERVICES UNIT</b>					
SSP603.02	Toilets	-	-	-	-
SSP603.04	Hand Washing Outlets	-	-	-	-
SSP603.05	Drinking Facilities	-	-	-	-
SSP603.11	Access Shower/Toilet	-	-	-	-
SSP603.30	Seating	-	-	-	-
<b>SSP605 STORAGE UNIT</b>					
SSP605.11	Bulk Store	-	-	-	-
SSP605.21	Cleaning Supplies Store	-	-	-	-
SSP605.31	Cleaning Distributed Store	-	-	-	-
<b>SSP607 ASSEMBLY COURT</b>					
SSP607.01	Assembly Area	-	-	-	-
SSP607.11	Flagpole	-	-	-	-
SSP607.21	Assembly Zone	-	-	-	-
<b>SSP608 PEDESTRIAN CIRCULATION</b>					
SSP608.01	Paved Areas	-	-	-	-
SSP608.02	Paved Access	-	-	-	-
<b>SSP609 VEHICULAR CIRCULATION</b>					
SSP609.01	Service Roads	-	-	-	-
SSP609.11	Bulk Waste Pad	-	-	-	-
SSP609.21	Car Parking	-	-	-	-
SSP609.51	Crossovers	-	-	-	-
SSP609.61	Student Set Down	-	-	-	-
<b>SSP610 OPEN SPACES</b>					
SSP610.01	Free Play Area	-	-	-	-



# Fire Protection

Schedule for BD/CD/ED School Rooms & Spaces

ID	ROOM/SPACE NAME	FD	FHR	PFE	OTH
SSP610.02	Passive Play/Open Areas	-	-	-	-
SSP610.11	Street Frontage Zone	-	-	-	-
SSP610.12	Active Zone	-	-	-	-
SSP610.13	Passive Zone	-	-	-	-
SSP610.14	Boundary Zone	-	-	-	-
SSP610.15	Out of Bounds Zone	-	-	-	-
SSP610.16	Special Function Zone	-	-	-	-
<b>SSP611 SERVICES</b>					
SSP611.01	Main Switchboard Cupboard	-	-	-	-
SSP611.02	Distribution Board Cupboard	-	-	-	-
SSP611.11	Services Zone	-	-	-	-
<b>SSP612 SITE</b>					
SSP612.01	Boundary Fencing	-	-	-	-
SSP612.03	Zone Fencing	-	-	-	-
SSP612.21	Signs	-	-	-	-