



Power

Schedule for BD/CD/ED School Rooms & Spaces

| ID | ROOM/SPACE NAME | GPO | CM | OTH |
|--|-------------------------------------|---|--|-----|
| SSP430 HOME BASE UNIT (IO/IS/P) | | | | |
| SSP430.01 | Home Base - IO | GENERAL POWER OUTLETS 4 double socket outlets | CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide | - |
| SSP430.02 | Home Base - IS/P | GENERAL POWER OUTLETS 5 double socket outlets and 2 pendant outlets | CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide | - |
| SSP430.11 | Home Base Store - IO/IS/P | - | - | - |
| SSP430.21 | Withdrawal - IO/IS/P | GENERAL POWER OUTLETS 1 double socket outlets \ | CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide | - |
| SSP430.31 | Practical Activities Area - IO/IS/P | GENERAL POWER OUTLETS 2 double socket outlets | CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide | - |
| SSP430.41 | Personal Effects Storage - IO/IS/P | - | - | - |
| SSP501 LIBRARY | | | | |
| SSP501.01 | Library Main Area | GENERAL POWER OUTLETS 12 double socket outlets | CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide | - |
| SSP501.11 | Office/Workroom | GENERAL POWER OUTLETS 3 double socket outlets and 1 single sock outlet | CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide | i |
| SSP501.21 | Communications Room | GENERAL POWER OUTLETS 5 double socket outlets and 3 single sock outlet | CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide | - |
| SSP501.32 | KLA Resource Store | - | - | - |
| SSP502 SPECIAL PROGRAMS UNIT | | | | |
| SSP502.04 | Special Programs Room - IO/IS/P | GENERAL POWER OUTLETS 4 double socket outlets | CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide | - |
| SSP502.16 | Kitchenette - IO/IS/P | GENERAL POWER OUTLETS 2 double socket outlets and 3 single sock outlet | CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide | - |
| SSP502.20 | Special Programs Store | - | - | - |
| SSP503 MULTIPURPOSE SPACE | | | | |
| SSP503.01 | Multipurpose Space | GENERAL POWER OUTLETS 6 double socket outlets | CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide | - |
| SSP503.11 | Chair Store | - | - | - |



Power

Schedule for BD/CD/ED School Rooms & Spaces

| ID | ROOM/SPACE NAME | GPO | CM | OTH |
|--|-------------------------------|--|--|-----|
| SSP503.22 | PE Store | - | - | - |
| SSP503.33 | Sports Store | GENERAL POWER OUTLETS 1 single socket outlet | CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide | - |
| SSP504 COVERED OUTDOOR LEARNING AREA (COLA) | | | | |
| SSP504.02 | Covered Outdoor Learning Area | - | - | - |
| SSP504.07 | Covered Outdoor Seating Area | - | - | - |
| SSP502 GAMES | | | | |
| SSP505.02 | Games Court | GENERAL POWER OUTLETS 1 double socket outlet | CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide | - |
| SSP601 ADMINISTRATION UNIT | | | | |
| SSP601.01 | Entry Vestibule | GENERAL POWER OUTLETS 2 single socket outlets | CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide | - |
| SSP601.11 | Principal | GENERAL POWER OUTLETS 3 double socket outlets | CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide | - |
| SSP601.13 | Deputy Principal | GENERAL POWER OUTLETS 3 double socket outlets | CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide | - |
| SSP601.15 | Interview | GENERAL POWER OUTLETS 3 double socket outlets | CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide | - |
| SSP601.16 | Interview/Office | GENERAL POWER OUTLETS 4 double socket outlets | CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide | - |
| SSP601.21 | Clerical/Printing | GENERAL POWER OUTLETS 4 double socket outlets | CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide | - |
| SSP601.41 | Security Store | GENERAL POWER OUTLETS 1 double socket outlets | CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide | - |
| SSP601.51 | Sick Bay | GENERAL POWER OUTLETS 1 double socket outlets | CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide | - |
| SSP601.81 | Entrance Zone | - | - | - |

SSP602 STAFF UNIT



Power

Schedule for BD/CD/ED School Rooms & Spaces

| ID | ROOM/SPACE NAME | GPO | CM | OTH |
|-------------------------------------|----------------------------|---|--|-----|
| SSP602.01 | Staff Room | GENERAL POWER OUTLETS 2 double socket outlets and 2 single sock outlet | CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide | - |
| SSP602.21 | Staff Room Annexe | GENERAL POWER OUTLETS 3 double socket outlets | CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide | - |
| SSP602.30 | Staff Toilet | - | - | - |
| SSP603 STUDENT SERVICES UNIT | | | | |
| SSP603.02 | Toilets | - | - | - |
| SSP603.04 | Hand Washing Outlets | - | - | - |
| SSP603.05 | Drinking Facilities | - | - | - |
| SSP603.10 | Access Toilets/Shower | GENERAL POWER OUTLETS 1 single socket outlet | CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide | - |
| SSP603.21 | Laundry | GENERAL POWER OUTLETS 2 double socket outlets | CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide | - |
| SSP603.30 | Seating | - | - | - |
| SSP605 STORAGE UNIT | | | | |
| SSP605.01 | Garden Store | GENERAL POWER OUTLETS 1 single socket outlet | CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide | - |
| SSP605.11 | Bulk Store | GENERAL POWER OUTLETS 1 double socket outlet | CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide | - |
| SSP605.21 | Cleaning Supplies Store | GENERAL POWER OUTLETS 1 double socket outlet | CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide | - |
| SSP605.31 | Cleaning Distributed Store | - | - | - |
| SSP605.41 | General Store | GENERAL POWER OUTLETS 3 double socket outlet | CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide | - |
| SSP607 ASSEMBLY COURT | | | | |
| SSP607.01 | Assembly Area | GENERAL POWER OUTLETS 1 double socket outlet | CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide | - |
| SSP607.11 | Flagpole | - | - | - |



Power

Schedule for BD/CD/ED School Rooms & Spaces

| ID | ROOM/SPACE NAME | GPO | CM | OTH |
|--------------------------------------|-----------------------------|-----|----|-----|
| SSP607.21 | Assembly Zone | - | - | - |
| SSP608 PEDESTRIAN CIRCULATION | | | | |
| SSP608.01 | Paved Areas | - | - | - |
| SSP608.02 | Paved Access | - | - | - |
| SSP609 VEHICULAR CIRCULATION | | | | |
| SSP609.01 | Service Roads | - | - | - |
| SSP609.11 | Bulk Waste Pad | - | - | - |
| SSP609.21 | Car Parking | - | - | - |
| SSP609.51 | Crossovers | - | - | - |
| SSP609.61 | Student Set Down | - | - | - |
| SSP609.62 | Porte Cochere | - | - | - |
| SSP610 OPEN SPACES | | | | |
| SSP610.01 | Free Play Area | - | - | - |
| SSP610.02 | Passive Play/Open Areas | - | - | - |
| SSP610.11 | Street Frontage Zone | - | - | - |
| SSP610.12 | Active Zone | - | - | - |
| SSP610.13 | Passive Zone | - | - | - |
| SSP610.14 | Boundary Zone | - | - | - |
| SSP610.15 | Out of Bounds Zone | - | - | - |
| SSP610.16 | Special Function Zone | - | - | - |
| SSP611 SERVICES | | | | |
| SSP611.01 | Main Switchboard Cupboard | - | - | - |
| SSP611.02 | Distribution Board Cupboard | - | - | - |
| SSP611.11 | Services Zone | - | - | - |
| SSP612 SITE | | | | |
| SSP612.01 | Boundary Fencing | - | - | - |
| SSP612.21 | Signs | - | - | - |